

Modified Well Yield Testing



15922 A.E. Mullinix Road | Woodbine, MD 21797
 410-984-1215
jeff@tpginspect.com

Site Address:
 Josh & Corrine Smith
 2900 Evergreen Way
 Ellicott City MD 21042

Well Information

Test Date: 7-2-13 Well Tag Number: not legible
 Well Depth: not given GPM at Drilling: not given

NOTES: The One Hour Well Yield Averaged 8.1 GPM

Seconds for 5

Minute	SEC/GAL	PSI	GPM
START	<u>19</u> _____	<u>40</u> _____	15.8
15	<u>35</u> _____	<u>40</u> _____	8.5
30	<u>37</u> _____	<u>40</u> _____	8.0
45	<u>42</u> _____	<u>40</u> _____	7.1
1Hour	<u>54</u> _____	<u>40</u> _____	5.5

This test is performed for informational purposes and not to be used as a predictor for future well performance.